

Certificate of Test

Job No.: NR7167

No. FNR 12046C

“Copyright CSIRO 2017 ©”

Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the specimen described below was tested by CSIRO Infrastructure Technologies/Future manufacturing Flagship in accordance with Australian Standard ISO 9239, Reaction to fire tests for floorings, Part 1: Determination of the burning behaviour using a radiant heat source, 2003, on behalf of:

Hainey Investments Pty Ltd
T/A Inspired Floorcoverings
32 Miller Road
TERRIGAL NSW 2260 AUSTRALIA

A full description of the test specimen and the complete test results are detailed in the Division's sponsored investigation report numbered FNR 11118.

SAMPLE

IDENTIFICATION: INSPIRED FLOORCOVERINGS FLINDERS RANGE

DESCRIPTION OF

SAMPLE: The sponsor described the tested specimen as timber patterned PVC plank floorcovering comprising three layers:

Layer 1: 0.55-mm thick PVC wear layer;
Layer 2: print film;
Layer 3: PVC backing.

The specimen was adhered to a 6-mm thick fibre-reinforced cement board using Polymer 265 adhesive applied with a 1-5 mm v-notch trowel.

Nominal thickness: 2.5 mm
Nominal mass: 4.3 kg/m²
Colour: natural oak

SAMPLE

CLASSIFICATION: Mean distance of flame travel: 100 mm
Average Critical Radiant Flux: 10.7 kW/m²
Average integrated smoke value: 41 %.min

Testing Officer: Heherson Alarde Date of Test: 24 April 2014

Issued on the 27th day of September 2017 without alterations or additions. Supersedes CSIRO Certificate of Test No. FNR 11118C issued on 26th April 2014.



Brett Roddy
Team Leader, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.

Accreditation No. 165 – Corporate Site No. 3625

Accredited for compliance with ISO/IEC 17025

CSIRO INFRASTRUCTURE TECHNOLOGIES

14 Julius Avenue, Riverside Corporate Park, North Ryde NSW 2113 AUSTRALIA
Telephone: 61 2 9490 5444 Facsimile: 61 2 9490 5555 www.csiro.au

