

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTa Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Inspired Floorcoverings
8 Loughlin Street
Rozelle NSW 2039

Test Number : 18-005280
Issue Date : 19/11/2018
Print Date : 19/11/2018

Sample Description Clients Ref : "Urban Range"
Tufted loop pile carpet tiles supplied adhered to FR cement sheet using P5
Colour : Blue
Nominal Composition : 100% Solution dyed nylon with cushion backing
Nominal Mass per Unit Area/Density : 23oz/yd²
Nominal Thickness : 9-10mm

AS/ISO 9239.1-2003 **Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source**

Date of Sample Arrival 05/09/2018

Date Tested 16/11/2018

CHF Value	1	2	3	Mean	
Length	5.5	3.7	3.7	4.3	kW/m ²
Width	5.7	-	-	-	kW/m ²

HF-30 Value	1	2	3	Mean	
Length	5.5	3.9	3.9	4.4	kW/m ²
Width	-	-	-	-	kW/m ²

Smoke Value	1	2	3	Mean	
Length	67	141	127	112	%.min
Width	49	-	-	-	%.min

Melting Yes

147974

30601

Page 1 of 2

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

- Chemical Testing : Accreditation No. 983
- Mechanical Testing : Accreditation No. 985
- Performance & Approvals Testing : Accreditation No. 1356



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTa Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTa Product Testing and AWTa Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTa Ltd.

APPROVED SIGNATORY

0204/11/06

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTa Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Inspired Floorcoverings
8 Loughlin Street
Rozelle NSW 2039

Test Number : 18-005280
Issue Date : 19/11/2018
Print Date : 19/11/2018

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was clamped as supplied by client prior to testing.

147974

30601

Page 2 of 2

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

- Chemical Testing	: Accreditation No.	983
- Mechanical Testing	: Accreditation No.	985
- Performance & Approvals Testing	: Accreditation No.	1356



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTa Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTa Product Testing and AWTa Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTa Ltd.

APPROVED SIGNATORY

0204/11/06

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR