

# CERTIFICATE OF ANALYSIS

**BELL**  
LABORATORIES

Inspired Floorcoverings Pty Ltd  
PO Box 575, Terrigal NSW 2260

PO Box 6064  
Hawthorn West, VIC 3122  
ABN 22 150 195 734  
admin@bell-labs.com.au  
T 1800 878 262  
F +613 9815 0448  
[bell-labs.com.au](http://bell-labs.com.au)

Date 18/02/2025

Certificate No: C 2502031-1

## VOLATILE ORGANIC CHEMICAL EMISSIONS

Report No.	J 2502031
Sample No.	2502031-1
Manufacturer	Inspired Floor Coverings
Product	Stonewall Onyx carpet tile
Product description	Nylon carpet tile, PVC backing
Product code, Lot No.	CT900803, BATCH 07
Date manufactured	13/11/2024
Date received	3/02/2025
Date tested	4/02/2025 (1 day)
Test methods	CDPH-IAQ V1.2 2017 "Standard Method for the Testing and Evaluation of VOC Emissions from Indoor Sources" ISO 10580:2010 "Test Method for VOC Emissions - resilient, textile and laminate floor coverings"
Room model	Private office
Emission surface	Floor
VOC's & Aldehydes	Pass
TVOC's	<450 µg/m <sup>2</sup> /h, <0.450 mg/m <sup>3</sup>

## QUALITY ASSURANCE

BELL Laboratories operates to ISO 17025 – General Requirements for the Competence of Testing and Calibration Laboratories which requires an ISO 9002 compliant quality system, suitable equipment/instrumentation and qualified, technically competent personnel.



Wayne Anderson  
Authorised Signatory